

Addenda# 1 to Project No: DFW_2015_018 Project Manual Specifications

Sandwich State Fish Hatchery Well Redevelopment and Turbine Pump Refurbishment and Replacement Project, Sandwich, Massachusetts

Issue Date: November 24, 2014

Information contained on Page 29 section 1.3 DESCRIPTION part A Sandwich Hatchery Well 2 of Well and Existing Equipment in the project manual for DFW_2015_018 has been found to be incorrect.

To the best of the Division's knowledge, following information is believed to be correct so replace Section 1.3(A) paragraph #2 on page 29 with the following:

The existing pump is a Goulds Model 7C 110 Ser No. ME 555057. It replaced the original Goulds pump in November 2008. In 2011 the impeller was replaced with a Goulds Model No. 7CLO stainless. The premium efficiency motor was installed new in 2008. It is a 20 HP US Motors 3 phase, 460 V, 23.2 amps and 3525 rpm.